

RESULTS FOR THE CALENDAR YEAR

2012

Report Date:
25/10/2012



POLLUTION MONITORING

As required by the NSW EPA under Section 66(6) of the POEO Act

TYPE OF MONITORING

Stack Gases

PREMISES DETAILS

TOOHEYS PTY LTD
29 NYRANG STREET
LIDCOMBE
NSW 2141
LOT 10 DP 1008367
ENVIRONMENTAL PROTECTION LICENCE No. 1167

SAMPLE POINT

Co-Generation Engine Stack EPL ID No.7

REQUIREMENTS

| Pollutant | Monitoring Frequency | Unit of Measure | Concentration Limit | Reference Conditions | Oxygen Correction |
|------------------------|----------------------|-------------------|-----------------------|----------------------|-------------------|
| Nitrogen Oxides | Once per quarter | mg/m ³ | 250 mg/m ³ | Dry, 273k, 101.3kPa | 5% |
| VOC as n-propane equiv | Once per quarter | mg/m ³ | 40 mg/m ³ | Dry, 273k, 101.3kPa | 5% |

RESULTS

| Survey Date | Quarter | Nitrogen Oxides (mg/m3) | Concentration Limit (mg/m3) | Comment |
|-------------|-----------------|-------------------------|-----------------------------|---|
| 7/03/2012 | Jan 12 - Mar 12 | 244 | 250 | The result is within the required limit |
| 23/05/2012 | Apr 12 - Jun 12 | 238 | 250 | The result is within the required limit |
| 19/07/2012 | Jul 12 - Sep 12 | 234 | 250 | The result is within the required limit |
| 21/09/2012 | Oct 12 - Dec 12 | 237 | 250 | The result is within the required limit |
| | | | | |

| Survey Date | Quarter | VOC as n-propane equiv (mg/m3) | Concentration Limit (mg/m3) | Comment |
|-------------|-----------------|--------------------------------|-----------------------------|---|
| 7/03/2012 | Jan 12 - Mar 12 | <7 | 40 | The result is within the required limit |
| 23/05/2012 | Apr 12 - Jun 12 | <5.9 | 40 | The result is within the required limit |
| 19/07/2012 | Jul 12 - Sep 12 | <7.42 | 40 | The result is within the required limit |
| 21/09/2012 | Oct 12 - Dec 12 | <2.09 | 40 | The result is within the required limit |
| | | | | |

Comments:

All monitoring results for the latest survey conducted 21/09/2012 are within the required limits